



मोतीलाल नेहरु कॉलेज Motilal Nehru College

(दिल्ली विश्वविद्यालय)
(University of Delhi)

संदर्भ : एमएनसी/बीजेएम/
Ref. : MNC/BJM/2018/149

बेनीतो हुआरेज मार्ग
नई दिल्ली-110021
Benito Juarez Marg,
New Delhi - 110021

Date:- 25.05.2018

Quotation Notice

Sealed quotation are invited from the firm who are enlisted currently with Delhi University, CPWD,NBCC,MESS.for Miscellaneous P/f of Desert Cooler at Motilal Nehru College, University of Delhi. The quotation should reach the undersigned latest by 12p.m on 11.05.2018. A copy of GST/ PAN /TAN number should be enclosed with the quotation. Please indicate on the top the envelopes " Quotation for further clarification you may contact office of college in all working days between 3.00 p.m to 5.00 p.m. The quotation will be opened on 11.05.2018 at 1.00 p.m Description of Items are given below-

Part-I

Sub:- Providing and fixing of Desert Cooler for room in Motilal Nehru College ,South Campus, University of Delhi.

S.NO	ITEM CODE	DESCRIPTION OF ITEMS	QTY	UNIT	RATE	AMOUNT
1	MR	Supplying and fixing of desert cooler with G.I long body 20 gauge with 18 " exhaust fan heavy duty 220 v with water pump & pad and size "25" x "25"x "46" making connection etc as require at site (crompton/khetan/cool home)	14	Nos		
2	MR	Providing and fixing of iron angles size 40x5, frame of size "36" x "26" x "26" for dessert cooler etc as require at site.	14	Nos		
3	MR	Making provision of cement frame for desert cooler "0.30" x "0.30" x "0.45" in cement mortar 1:4 (1 cement : 4 coarse sand and excavation of plaser in frame etc as require.	14	Nos		

CONTINUE PAGE 2



मोतीलाल नेहरु कॉलेज Motilal Nehru College

(दिल्ली विश्वविद्यालय)
(University of Delhi)

संदर्भ : एमएनसी/बीजेएम/
Ref. : MNC/BJM/2018/149

बेनीतो हुआरेज मार्ग
नई दिल्ली-110021
Benito Juarez Marg,
New Delhi - 110021

Part-II

Sub- Provision of Desert Cooler point in room no. 1 to 5 S/F TP&DB and 4x16 cable in pota cabin at Motilal Nehru College, South Campus, University of Delhi.

S.NO	ITEM CODE	DESCRIPTION OF ITEMS	QTY	UNIT	RATE	AMOUNT
1	MR	Supplying and fixing following size PVC insulated and PVC sheathed /XLPE power aluminum armoured cable of 1.1 KV grade of following size including clamped with 1mm thick saddle etc as require at site. 4x16 sqmm	80	Nos		
2	MR	Supplying and fixing following way prewired TP&N MCB distributin board of steel sheet of 415 volts on surface/ recess complete with loose wire box, terminal connectin for all incoming and outgoing circuits,duly prewired ith suitable size FR PVC insulated copper conductor up to terminal blocks, tinned copper bus bar, neutral link, earth wire, din bar, detachable gland plate, inter-connections, powder painted including earthing etc. as required. (but without MCB/RCCB/ isolator) 4 way (4+12)	1	Nos		
3	MR	Supplying and fixing 5 amps to 32 amps rating, 240/415 volts, "c" curve, miniature circuit breaker suitable for inductive load of following poles in the existing MCB DB complete with connection, testing and commissioning etc. as required. Single pole	12	Nos		
4	MR	Supplying and fixing following 63 amps, TPN MCB, 415 volts, in the existing MCB DB complete with connections, testing and commissioning etc. as required.	1	Nos		
5	MR	S/D the following size FRLS of PVC insulated copper conductor cable in the existing surface/recess PVC conduit required.				
a.	1.17.1	1x1.5 sqmm	250	Mtrs		
b.	1.17.20	2x4 sqmm	250	Mtrs		
6	2.10.1	Supplying and fixing following sizes of medium class PVC conduit/batten along with all accessories in surface/recess including cutting the wall and making good the same in case of recessed conduit as required				
a.	1.21.2	25mm	110	Mtrs		
b.	1.21.1	20mm	30	Mtrs		
7	MR	Supplying and fixing of following 32 amp, double pole MCB, 240 volts, in the existing MCB DB complete with connections, testing and commissioning etc. as required.	10	Nos		
8	MR	Supplying and fixing of 2 way enclosure for DP MCB and making connection etc. as required.	10	Nos		
9	MR	Supplying and making and termination with brass compression gland and aluminium lugs for following size of PVC insulated and PVC sheathed/XLPE aluminium conductor cable of 1.1 KV grade as required.				
a.	9.1.33	4x16 Sqmm	2	Nos		
10	5.2	Earthing with G.I pipe 4.5 meter long 40mm dia including accessories and providing masnory enclosure with cover plate charcoal/coke and salt as required.	1	set		
11	5.12	Providing and laying earth connection FRLsom earth electrode with 6 SWG dia wire in 15mm G.I pipe FRLsom earth electrode including connection wiwth G.I thimble excavation and refilling as required.	10	Mtrs		

Thanking You,

Yours Faithfully


Acting Principal